

RURAL MUNICIPALITY OF LAC PELLETIER NO. 107

BYLAW NO. 2022-07

A BYLAW TO AMEND BYLAW 2015-05 BEING A BYLAW RESPECTING FIRE RESTRICTIONS

The Council of the Rural Municipality of Lac Pelletier No. 107 in the Province of Saskatchewan enacts as follows:

1. That Bylaw 2015-05 respecting Fire Restrictions be amended to add PART II.A as follows:
 - a. Adoption and application of the National Fire Code of Canada
 - i. The National Fire Code, as amended or replaced from time to time, is adopted and made part of this Bylaw, such that every provision of the National Fire Code shall be considered a provision of this Bylaw.
 - ii. Any person who contravenes, violates or fails to comply with a provision of the National Fire Code or this Bylaw commits an offence under this Bylaw.
 - b. Building and Occupant Fire Safety – Fire Hazards – Combustible Materials
 - i. Combustible materials in and around buildings shall not be permitted to accumulate in quantities or locations that will constitute an undue fire hazard.
 1. Combustible materials constituting an undue fire hazard include unattended or overgrown grass or vegetation with a length or height in excess of 15 cm and the accumulation of combustible materials in quantity that can contribute to the intensity and spread of fire.
 2. There shall be a clear space of 6 metres between buildings and unattended or overgrown grass and vegetation.
 3. The total area of accumulated combustible materials shall not exceed 3m square and a height of 1 metre outside of a building on residential property
 - c. Flammable and Combustible Liquid – Container Storage and Handling – Outdoor storage
 - i. Not more than 50L of flammable liquids and combustible liquids, of which not more than 30L shall be Class I liquids, are permitted to be stored outside of a building on an assembly or residential property.

Reeve

Administrator

Read a third time and adopted this 10th day of May, 2022.